


**PROFORMA FOR SAFE DRINKING WATER AND SANITARY  
CONDITION CERTIFICATE**

No. 180...

Date 07.02.2024

It is certified that an inspection team headed by Er. ATIF HUSSAIN EXECUTIVE ENGINEER from DIVISION OFFICE U.P JAL NIGAM (RURAL) DISTRICT- MAHARAJGANJ (Name of Department/Office) inspected the Rasin School, Nagar Panchyat Partawal Bazar, District- Maharajganj (Name & Address of the School) on 07.02.2024 and found that the Rasin School (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/UT Govt.


The above valid for a period of 07.02.2024 to 06.08.2024

  
Executive Engineer  
Division Office  
U.P. Jal Nigar (Rural)  
District- Maharajganj

To,

Rasin School,  
Nagar Panchyat Partawal Bazar,  
District- Maharajganj.

  
PRINCIPAL  
RASIN SCHOOL  
Partawal Chowk - Maharajganj

  
(-सि. प्रकाश सिंह)  
MANAGER  
RASIN SCHOOL  
Partawal Chowk - Maharajganj



कार्यालय,  
अधिसासी अभियन्ता,  
खण्ड कार्यालय, उ०प्र० जल निगम(ग्रामीण),  
महाराजगंज

पत्रांक: 180 / विविध-35 / 15 दिनांक: 07/02/2024  
सेवा में,

प्रधानाचार्य,  
रसिन स्कूल,  
नगर पंचायत परतावल,  
जनपद-महाराजगंज

विषय:- पानी की शुद्धता की जाँच रिपोर्ट के सन्दर्भ में।

महोदय,

उपरोक्त विषयक आपके द्वारा दिनांक 03.02.2024 को 1 नग जल नमूनों का गुणवत्ता परीक्षण हेतु उपलब्ध कराये गये है। प्राप्त 1 नग जल नमूनों का परीक्षण इस खण्ड के विभागीय प्रयोगशाला में किया गया, जिसका परीक्षण रिपोर्ट पत्र के साथ संलग्नकर प्रेषित है।

संलग्नक- 1 नग जल परीक्षण रिपोर्ट।

भवदीय

अधिसासी अभियन्ता

पुं०सं० एवं दिनांक तदैव:-

प्रतिलिपि: निम्नलिखित को सूचनार्थ एवं आवश्यक कार्यवाही हेतु प्रेषित।

1. श्री महेश चन्द्र आजाद सहायक अभियन्ता (प्रयोगशाला)।
2. श्री विदोस यादव, जूनियर इंजीनियर (प्रयोगशाला)।

अधिसासी अभियन्ता

PRINCIPAL  
RASIN SCHOOL

Partawal Chowk - Maharajganj

Sri Anubhush Singh  
(अधिसासी अभियन्ता)

MANAGER  
RASIN SCHOOL  
Partawal Chowk - Maharajganj





**District Level Water Analysis Laboratory,  
U.P. Jal Nigam(Rural), Maharajganj**  
Rampur Satbhariya Water Supply Campus, Gorakhpur Road,  
District-Maharajganj-273303

Lab ID: T-8716

Rept. No. UPJNMRJ/JAN/138

Date:- 07/02/2024


Page No. 1/2

### Technical Data of Analysis

S.No.	Analysed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Conductivity	134.60	mS/cm	NA	NA	IS 3025 (Part 14) : 2017
2	Sulphate	1.50	mg/L	200.00	400.00	IS 3025 (Part 24) : 2022
3	Nitrate	1.24	mg/L	45.00	No relaxation	IS 3025 (Part 34) : 2019
4	Iron	0.00	mg/L	1.00	No relaxation	IS 3025 (Part 53) : 2019
5	Arsenic	0.00	mg/L	0.01	No relaxation	IS 3025 (Part 37) : 2022
6	Floride	0.00	mg/L	1.00	1.50	IS 3025 (Part 60) : 2019

- Note:-**
1. This Certificate refers only to the particular sample(s) submitted for testing.
  2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has
  3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
  4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless



  
(Sushil Kumar)  
D.E.O.  
Prepared By

  
(Radheyshyam Rawat)  
Quality Manager  
Authorized Signatory  
Mob.No. 8858396541

Lab E-Mail ID :- ritikalalmrj@gmail.com

End of Test Report

  
**PRINCIPAL**  
RASIN SCHOOL  
Partawal Chowk - Maharajganj

  
()  
**MANAGER**  
RASIN SCHOOL  
Partawal Chowk - Maharajganj





## District Level Water Analysis Laboratory, U.P. Jal Nigam(Rural), Maharajganj

Rampur Satbhariya Water Supply Campus, Gorakhpur Road,  
District-Maharajganj-273303



TC-12224

Lab ID: T-8716

### Analysis Report

Rept. No. UPJNMRJ/JAN/138

Date:- 07/02/2024

Page No. 1/2

Customer Name - Rasin School

Address - Nagar Panchyat Partawal Bazar, District- Maharajganj

Reference Letter No.-

#### Basic Details of sample

District- Maharajganj		Nagar Panchyat- Partawal	
Gram Panchayat/ Nagar	Partawal Chauk	Village/Nagar	Partawal Chauk
Habitation-	Khas	Location	Rasin School
Water Source	R.O.		
Quantity of Sample	1500ml	Date of S.C.	03.02.2024
Receiving Date	03.02.2024	S. Collector	By Customer
Sample Receive	Brijesh Yadav	Analysis Completion Date-	07.02.2024
Analysis Start Date	03.02.2024		
Temperature - 25 +C		Relative Humidity - 50+-15%	

#### Technical Data of Analysis

S.No.	Analysed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Turbidity	0.96	NTU	1.00	5.00	IS 3025 (Part 10) : 2023
2	pH	8.08	-	6.5 - 8.5	No relaxation	IS 3025 (Part 11) : 2022
3	TDS	67.32	mg/L	500.00	2000.00	IS 3025 (Part 16) : 2023
4	Total Hardness	104.66	mg/L	200.00	600.00	IS 3025 (Part 21) : 2019
5	Total Alkanyity	122.00	mg/L	200.00	600.00	IS 3025 (Part 23) : 2023
6	Chloride as Cl	15.66	mg/L	250.00	1000.00	IS 3025 (Part 32) : 2019
7	Calcium	65.28	mg/L	75.00	200.00	IS 3025 (Part 40) : 2019
8	Magnisum	9.75	mg/L	30.00	100.00	IS 3025 (Part 46) : 2019
9	Colour	87.00	Hazen	5.00	15.00	IS 3025 (Part 4) : 2021

Note:-

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless.

  
(Sushil Kumar)

D.E.O.


Prepared By

  
(Radheyshyam Rawat)  
Quality Manager  
Authorized Signatory

Lab E-Mail ID :- ritikalalmrj@gmail.com

Mob.No. 8858396541

  
**PRINCIPAL**  
RASIN SCHOOL  
Partawal Chowk - Maharajganj

  
(Sushil Kumar)  
**MANAGER**  
RASIN SCHOOL  
Partawal Chowk - Maharajganj